

# EVASOLK



Bundesministerium  
für Umwelt, Naturschutz  
und Reaktorsicherheit



## Evaluation of Solar Cooling in Comparison to Reference Technologies



Björn Nienborg  
Edo Wiemken  
Anna Raquel Petry Elias

Fraunhofer Institute for Solar Energy  
Systems ISE


Partners: ILK Dresden, ZAE Bayern

IEA SHC Task 48 – 3<sup>rd</sup> Expert Meeting  
Gleisdorf, Austria

September 10-11, 2012


[www.ise.fraunhofer.de](http://www.ise.fraunhofer.de)

# EVASOLK - Perspectives of solar cooling (closed cycle systems)



©Fraunhofer ISE

# EVASOLK - Perspectives of solar cooling (closed cycle systems)



©Fraunhofer ISE


## Reference technology: monitoring

- Conventional installations; cross-section of technologies
- Monitoring by ILK Dresden, ZAE Bayern


	Technology	Rated capacity [ kW ]	Distribution	Monitoring status	Remark
<b>Building cooling (comfort air-conditioning)</b>					
1	Chilled water	13.1	Fan coils	running	
2	Chilled water	46.6	Ventilation	running	
3	Chilled water	60	Ventilation	running	
4	Mono-split	2.65	Fan coils	running	Type: hardware store
5	Mono-split	5.0	Fan coils	running	Type: brand supplier
6	Multi-split	40	Fan coils	running	6 condensor units
<b>Commercial / process cooling</b>					
7	Normal cooling	17	Cooling cell	running	brine system
8	Normal cooling	2	Cooling cell	running	direct evaporation

# Reference technology: monitoring

- Performance of conventional installations
- Data base for models in comparative study
- ongoing



# EVASOLK - Perspectives of solar cooling (closed cycle systems)



©Fraunhofer ISE

# Comparative study: solar cooling in buildings

©Fraunhofer ISE

Balance:

- electricity,
- fuel,
- primary energy
- CO<sub>2</sub> emission
- Life cycle costs (20 a)

**R** Residential (Multi-family house)

**H** Hotel building


**O** Office building

Use:

**C** = cooling


**H** = heating

**DHW** = domestic hot water



# Comparative study: solar cooling in buildings

©Fraunhofer ISE







# Comparative study: solar cooling in buildings

- Basic approach:
  - Annual simulation with TRNSYS;  
generic models (TDC, CCH, HP, collectors, ..)
  - Cost curves for key components (present costs)
  - Country specific energy prices
  - Primary energy savings and CO<sub>2</sub>-avoidance calculation in comparison to reference with country specific conversion numbers
  - Including emissions of typical refrigerant losses
  - Life cycle: 20a (collectors, TDC); 15a (CCH, HP)
  - Capital costs: rate of interest 5%
  - Annual energy price increase: 5% (electricity), 3% (natural gas)

# Overview solar fractions




## Variations:

- location
- TDC-Type
- FPC: 3...6 m<sup>2</sup>/kW<sub>P\_TDC</sub>
- ETC: 2.5...5.5 m<sup>2</sup>/kW<sub>P\_TDC</sub>

Cold backup: Air-cooled chiller

Reference: Multi-Split-System



# Evaluation

- Combined economic – primary energy related evaluation figure:

- Costs of saved Primary Energy

$$\mathbf{CPE_{LCC} = \Delta LCC / (PE_{Ref} - PE_{Sol})} \quad \text{€ / kWh}_{PE\_saved}$$



with

$\Delta LCC$  = (Life cycle cost, Solar system – Life cycle cost, Reference)  
LCC include investment and capital costs, operation and maintenance costs of 20 years life cycle

$(PE_{Ref} - PE_{Sol})$  = difference in PE demand between Reference and solar configuration within life cycle (20a)

- **Precondition:** primary energy is saved  $\Rightarrow (PE_{Ref} - PE_{Sol}) > 0$
    - then:  $CPE_{LCC}$  is positive in case of higher life cycle costs of solar based system
    - In case, solar based system shows lower life cycle costs than reference:  $CPE_{LCC}$  is negative  
(division of one benefit by another: not useful)

# Übersicht Kosten der Primärenergieeinsparung




Variations:

- location
- TDC-Type
- FPC: 3...6 m<sup>2</sup>/kW<sub>P\_TDC</sub>
- ETC: 2.5...5.5 m<sup>2</sup>/kW<sub>P\_TDC</sub>


Cold backup: Air-cooled chiller

Reference: Multi-Split-System



## Effect of investment costs


- Configuration with lowest PE-avoidance costs
- **S0** : present cost situation
- $C_{LCC} / Q_{th}$ : costs per kWh thermal useful energy  
 $Q_{th}$ : thermal useful energy [ $\Sigma (Q_{Heating}, Q_{Cooling}, Q_{DHW})$ ] within life cycle



## Effect of investment costs

- **S1** : collector system costs: -10% \*


\* goal Roadmap of BSW: Solar thermal system costs -14% until 2020



## Effect of investment costs

- **S2** : collector system costs: -10%, TDC system costs -25% \*


\* goal Roadmap of BSW: Solar thermal system costs -14% until 2020;  
forecast small/medium TDC-systems: -35% until 2020 (Dr. U. Jakob, Green Chiller)



## Effect of investment costs

- **S3** : collector system costs: -40%, TDC system costs -50% \*

\* goal Roadmap of BSW: Solar thermal system costs -43% until 2030;  
forecast small/medium TDC-systems: -50% until 2030 (Dr. U. Jakob, Green Chiller)





# Effect of thermally driven chiller capacity

- Reducing capacity of thermally driven chiller (backup chiller size remains constant)
- $P_{TDC}$ : **75%** of max. cooling load (regular layout in case study)

$P_{TDC}$ :

85 kW (Toulouse)

94 kW (Athens)

flat-plate collector


3-6 m<sup>2</sup> per kW  $P_{TDC}$

cold backup:

el. compr. chiller

heat backup:

gas boiler



# Effect of thermally driven chiller capacity

- Reducing capacity of thermally driven chiller (backup chiller size remains constant)
- $P_{TDC}$ : **50%** of max. cooling load

$P_{TDC}$ :

56 kW (Toulouse)

62 kW (Athens)

flat-plate collector


5-8 m<sup>2</sup> per kW  $P_{TDC}$

cold backup:

el. compr. chiller

heat backup:

gas boiler



# Effect of thermally driven chiller capacity

- Reducing capacity of thermally driven chiller (backup chiller size remains constant)
- $P_{TDC}$ : **33%** of max. cooling load

$P_{TDC}$ :

38 kW (Toulouse)

42 kW (Athens)

flat-plate collector


5-8 m<sup>2</sup> per kW  $P_{TDC}$

cold backup:

el. compr. chiller

heat backup:

gas boiler



# Costs of PE-saving: Sensitivity

- Effect on CPE by variation of +/- 10% relative of governing factors


Sensitivity to Cost per saved kWh primary energy: <b>Hotel, Palermo</b> , flat plate collector of size 5 m <sup>2</sup> per kW chilling capacity of thermally driven chiller (absorption)		
	Relative change % of rated value	Influence to CPE <sub>LCC</sub> in %
Electricity price	+ 10	- 3
	- 10	+ 3
Fossil fuel price	+ 10	- 3
	- 10	+ 4
Seasonal efficiency of cooling system in reference	+ 10	+ 15
	- 10	- 12
Cost of collector	+ 10	+ 8
	- 10	- 7
Cost of thermally driven chiller (TDC)	+ 10	+ 6
	- 10	- 6
Installation cost	+ 10	+ 4
	- 10	- 3
Interest rate	+ 10	+ 6
	- 10	- 6
Annual increase energy cost (electricity + fuel)	+ 10	- 3
	- 10	+ 3

Hotel, small  
flat-plate collector  
cold backup:  
el. compr. chiller  
heat backup:  
gas boiler

©Fraunhofer ISE

# Comparison ST - PV

- 2.5...6 m<sup>2</sup>/kW<sub>P\_TDC</sub> for ST and PV
- PV: grid connected (unlimited storage)




# Summary (1)

- Investigated so far: solar cooling with 1-effect thermally driven technology in standard configurations
- At appropriated sites, high PE savings and solar fractions possible
- Most promising: applications with additional use of solar thermal system (e.g., high DHW demand)
- Life cycle costs still higher than reference (no funding considered)
- To compete economically with reference systems: pronounced decrease in component costs (collector, thermally driven chiller) is necessary
- With cost projection of industrial associations: economic equality to reference obtained, but not in a short term
- High sensitivity to EER in reference: efforts necessary to increase electrical efficiency of solar cooling systems (with cold backup: no comfortable distance to reference)
- Sensitivity to energy price: small


## Summary (2)

- Further measures for optimization
  - avoidance of cold backup, where compatible with comfort requirements
  - careful decrease of TDC capacity (no peak-load design)
  - use of medium-temperature heat (e.g. for DHW pre-heating, not studied)
- Next steps
  - Comparison with reference + grid connected PV
  - Systems with heat pumps
  - Systems with concentrating collectors, 2-effect TDC
  - Comparative study on solar process cooling (ILK Dresden)
  - Evaluation of reference technology (ZAE Bayern, ILK Dresden)

EVASOLK is supported by the federal Ministry for the Environment, Nature Conservation and Nuclear Safety (FKZ 0325966 A)



Thank-you for your attention!



Fraunhofer Institute for Solar Energy Systems ISE

Björn Nienborg

[www.ise.fraunhofer.de](http://www.ise.fraunhofer.de)

[bjoern.nienborg@ise.fraunhofer.de](mailto:bjoern.nienborg@ise.fraunhofer.de)




# EER

- sEER of solar thermal systems (H052 configurations) : 7.5 – 8.9  
(collector and TDC system with pumps, heat rejection)
- average sEER<sub>ST\_total</sub>: total system incl. backup chiller, chilled water pump  
(average of configurations per site)


sEER:  

$$\frac{\text{cold production}}{\text{electricity input}}$$





# EER

- sEER of solar thermal systems (H052 configurations) : 7.5 – 8.9  
(collector and TDC system with pumps, heat rejection)
- average sEER<sub>ST\_total</sub>: total system incl. backup chiller, chilled water pump  
(average of configurations per site)



# Example: Residential (1)



© Fraunhofer ISE



- Small application: multi-family building (< 20 kW capacity TDC)
- Cold backup: el. compression
- Reference: multi-split system
- Variations:
  - Collector size
  - Collector type
  - Ab-/Adsorption chiller

specific collector area:


3	4	5	6	m <sup>2</sup> / kW TDC_capacity	: FPC
2.5	3.5	4.5	5.5	m <sup>2</sup> / kW TDC_capacity	: ETC

©Fraunhofer ISE

# Example: Residential (1)






- Small application: multi-family building (< 20 kW capacity TDC)
- Cold backup: el. compression
- Reference: multi-split system





# Example: Office

- Office building (> 100 kW capacity TDC)
- Cold backup: el. compression
- Reference: multi-split system




# Comparative study: solar cooling in buildings



- Base for cost curves components:
  - Survey in IEA SHC Task 38
  - Realised systems, own queries
  - Catalogue sales prices



# Example: Hotel



- Hotel building (> 70 kW capacity TDC)
- Cold backup: el. compression
- Reference: multi-split system



©Fraunhofer ISE