







Solar Thermal or Photovoltaic Cooling?

Prof. Dr. habil. Ursula Eicker
Research center sustainable energy
technologies – zafh.net
University of Applied Sciences Stuttgart

Solar cooling systems




PV Module Prices Development 2009 - 2011



Source: www.solarserver.de



Methodology: Simulation studies in planning phase




Small office building European conditions

Task 25 Office building in three climates (Palermo, Madrid, Stuttgart)


- Absorption 35 kW (COP = 0.7) versus Compression 30 to 50 kW
- Backup CCM 10kW (COP= 3.5)
- Flat plate/vacuum tube collectors – Monocrystalline Silicon
- Heat storage (5m³)
- Cold storage (1m³)
- Wet cooling tower



Compressor performance model




Cooling loads




CASE	City	Uwall (W/m² K)	Internal loads	Sun Protection	Annual cooling load (kWh/m²)	Annual heating load (kWh/m²)	Maximum cooling load (W/m²)
Case 1	Palermo	1.1	low	yes	46	18	38.0
Case 2	Palermo	0.41	low	yes	61	0	31.9
Case 3	Palermo	1.1	high	no	94	2	54.1
Case 4	Palermo	0.41	high	no	141	0	39.4
Case 5	Madrid	0.66	low	yes	34	11	34.4
Case 6	Madrid	0.41	low	yes	36	5	32.6
Case 7	Madrid	0.66	high	no	88	0	35.6
Case 8	Madrid	0.41	high	no	97	0	34.2
Case 9	Stuttgart	1.1	low	yes	8	56	23.8
Case 10	Stuttgart	0.41	low	yes	17	20	22.6
Case 11	Stuttgart	1.1	high	no	31	25	29.8
Case 12	Stuttgart	0.41	high	no	54	2	30.2


Solar fraction for PV and ST cooling




Electrical energy requirement




Reduction of auxiliary energy by optimised control




Primary energy savings for cooling




Cost comparison



Total annual costs



Cost of cooling production




CASE	Photovoltaic cooling system		Thermal solar cooling system	
	PV Export Grid	Feed in tariff	Heat use	Heat price
A	No	-	No	-
B	yes	Germany 0.2455 €/kWh Italy 0.2085 €/kWh Spain 0.1855 €/kWh	Yes	Germany 0.0572 €/kWh Italy 0.0542 €/kWh Spain 0.0506 €/kWh
C	yes	Germany 0.42 €/kWh Italy 0.33 €/kWh Spain 0.4 €/kWh	-	-
D	yes	Germany 0.19 €/kWh Italy 0.2085 €/kWh Spain 0.1855 €/kWh	Yes	Germany 0.114 €/kWh Italy 0.108 €/kWh Spain 0.101 €/kWh

Design project Baden Württemberg State Ministry




Motivation:
 strong summer overheating, no night ventilation
 Renewable heat law: 15 % solar thermal for heating and cooling (of public buildings)

Result:
 25-50% solar fraction with thermal cooling system



Recommendation for small systems



PV most cost effective – but low solar fractions of 20-30%

Solar thermal cooling for base load to reduce costs

Peak loads with electric compression + PV with grid feed in

Large solar cooling systems for mediterranean climates



Cairo office building
15100 m² surface
52 W/m² cooling load
130 kWh/m² cooling
energy demand

Comparison of large multi-effect systems

Case	Chiller Type	Cooling Capacity	Collector Type	Collector Area		Storage Tank	
				brut	aperture	hot	cold
Case 1	Single Effect	422 kW	Vacuum Tube	2025 m ²	1350 m ²	20 m ³	10 m ³
Case 2	Double Effect	500 kW	Linear Fresnel	2050 m ²	1320 m ²	20 m ³	10 m ³
Case 3	Triple Effect	563 kW	Linear Fresnel	1280 m²	800 m²	-- m ³	10 m ³



THERMAX, single effect
ProChill LT12C



Shuangliang, double effect
500 kW




Kawasaki Sigma, triple effect
Ace CF01-10-0001


1

8


Absorption Cooling Fraction and Solar System Efficiency




Heating Energy Consumption and Average COP_{th}




Primary Energy Efficiency



System Costs Including Installation and Integration



Overall Cooling Costs / Office Building in Cairo, Egypt




Prices: Gas = 0.0174 €/kWh
 Source: www.worldtribune.com

Electricity = 0.062 €/kWh
 Inflation rate = 5.6%/a

Water = 1.6 € / m³
 Discount rate = 6%/a

Overall Cooling Costs / Office Building in Cyprus



Prices: Gas = 0.101 €/kWh

Electricity = 0.230 €/kWh

Water = 4.0 € / m³

Inflation rate = 5.6%/a

Discount rate = 6%/a

Conclusion

- Solar thermal and photovoltaic cooling allows for primary energy savings of 30 to 50% in typical office building projects
- Good partial load control is important for primary energy savings
- For reduced feed in tariffs and increasing heat costs the total costs of PV and solar thermal cooling are comparable
- For long operating hours solar cooling is competitive with conventional cooling
- The primary energy efficiency of solar thermal cooling is comparable or higher than photovoltaic cooling, especially when double or triple effect chillers are used