IEA SHC Task 48 7th expert meeting

Quality assurance and support measures for Solar Cooling

DHW/Cooling hybrid strategy for solar cooling:




Second Summer monitoring results in South of France

Daniel MUGNIER – Garching, 29/09/2014



Hydraulic principle



Substation of DHW production (Storage & backup)






Hydraulic scheme

Solar production

DHW distribution



Summary of results for Summer 2013

	Unit	Value
Irradiation	kWh	104 000
Useful solar energy	kWh	30 000
Absorption generator	kWh	9 800
Absorption evaporator	kWh	6 000
DHW energy	kWh	18 000
Electrical energy	kWh	2 000
Thermal COP	(-)	0.60
Electrical Efficiency	(-)	12.2
Water Consumption	m3	60

System important advantage:

=> <u>full complementarity</u> between solar cooling and solar DHW

Simplicity of functionning:

=> No control issue (easy interaction Cooling <-> DHW)





Full year balance (march 2013/ mars 2014)

	DHW Production (kWh)	Cooling Production (kWh)	Parasitic elec. Consumption (kWh)	Useful Solar Yield (kWh/m2)	Overal elec efficiency (-)
from 18/03/2013	4 654	0	110	19.4	42.3
april 2013	11 588	0	290	48.3	40.0
may 2013	16 478	0	380	68.7	43.4
june 2013	7 497	2 765	902	42.8	13.4
july 2013	9 482	3 983	1 190	56.1	13.5
august 2013	8 628	1 970	840	44.2	14.2
september 2013	9 316	676	554	41.6	18.9
october 2013	7 843	0	240	32.7	32.7
november 2013	4 789	0	220	20.0	21.8
december 2013	3 851	0	157	16.0	24.6
january 2014	3 734	0	190	15.6	19.7
february 2014	6 435	0	218	26.8	29.5
march 2014	12 860	0	348	53.6	30.9
april 2014	14 085	0	360	58.7	39.1
may 2014	12 633	281	326	54.0	40.2
june 2014	8 847	944	685	39.7	15.2
july 2014	5 586	2 959	851	26.8	12.4
TOTAL	148 308	13 578	7 861	674.5	20.6


^{*} elec consumption linked to the solar useful production (pumps solar, DHW, generator, evaporator, condensor circuits) without measuring back up elec consumption.

Global Electrical efficiency of nearly 21 in average for a full year and a solar yield of 674 kWh/m².y






Monitoring results for Summer 2014







Monitoring results for Summer 2014







Summary of the cooling season 2014

	Unit	Value 2014	Value 2013
Irradiation	kWh	24 500	30 000
Useful solar energy	kWh	9 000	9 800
Absorption generator	kWh	5 700	6 000
Absorption evaporator	kWh	11 300	18 000
DHW energy	kWh	1 750	2 000
Electrical energy	(-)	0.60	0.60
Thermal COP	(-)	12	12.2
Electrical Efficiency	m3	35	60

Irradiation in 2014 15% less than in 2013 (bad Summer weather !!)

Electrical efficiency still so high (12)

IMPROVEMENT: division by nearly 2 of the water consumption

Robustness of the installation (no damage from 2013)











Thanks for your attention!

<u>Contact</u>: Daniel Mugnier, TECSOL daniel.mugnier@tecsol.fr



