

Innovative and Energy Efficient

**Concept for Solar Cooling
(DHW/Cooling Hybrid Strategy):**

Practical First Results



Daniel MUGNIER

SHC Conference 2012
San Francisco, 10th July 2012

Introduction

* Long history in France for solar cooling
(1980-2011)



However, special national conditions for solar cooling :

- **Mild** climate (cooling season especially in South of France)
- **Low energy price** (one of the lowest in the World for electricity)
- **Not very good feedback** till now on performance levels (technical dysfunctionning, low economical interest, lack of providers)

⇒ Important need to structure the sector & get Full Best practice

Big challenge : which system/project to follow up the story in 2012 ?

Introduction

Solution :

- Emergence Program (high incentive against guarantee of results)
- Extend the solar resource use as much as possible
⇒ Idea to go to a mix DHW (instead of heating) + cooling system
- Find a site where the system integration is possible including a simple scheme and simple working conditions
- Find a customer motivated for such an application

« Amiral block » Solar DHW/Cooling project in Montpellier !

Targeted building description



Montpellier Heating and System net utilities
=> System owner



TECSOL : engineering company



AXIMA : Company in charge of
the works



Building A view

Existing Building block in ZAC Jacques Coeur in Port Marianne area
(Montpellier, France, built in 2010)

2 parts : building A & B (mini district)

Building A : 11 000 m² for offices and shops

Building B : 10 600 m² with 167 dwellings



Buildings situation




Load


Load : real monitored data from 2010 to 2011

DHW + cooling = 46 kWh/m².y \Rightarrow 1 GWh/y

Heating + cooling equipments : compression chillers + gas burners
(900 kW) (700 kW)



DHW load on a yearly basis



Cooling load on a yearly basis

Load & system strategy

Sizing strategy :


- available place on the roof
- simplicity & maximum yield



Picture of the collector field

⇒ nearly 500 m² available on different locations on the Block A roof => 240 m² solar collector


- DHW only in Winter + cooling (if possible +DHW) in Summer



Solar collector position on the roof

System description


- **240 m² double glazed flat plate collectors**
- **one 35 kW absorption chiller**
- solar circuit in drainback mode (with water glycol + HX)



Double glazed solar collector




Solar collector fields in drainback mode



Drainback principle

- one **1500 liter hot buffer storage tank**
 - DHW preheating
- (+ 10 m³ DHW additional storage capacity in Building B for dwellings)


Hydraulic principle



Hydraulic scheme

DHW distribution

Solar production



Drainback system

Cold production
Anti legionella adiabatic cooling tower



Expected results

	DHW production (kWh)	Cooling production (kWh)	Electric consumption (kWh)	Solar productivity* (kWh/m ²)	Electrical COP (-)	Solar fraction (%)
January	2 476	0	256	10,3	9,7	7,7 %
February	4 694	0	371	19,6	12,7	19,1 %
March	11 073	0	566	46,1	19,6	22,2 %
April	16 252	228	723	68,7	22,8	17,3 %
May	18 556	1 843	892	85,0	22,9	18,7 %
June	14 002	3 033	938	71,0	18,2	16,8 %
July	12 083	7 348	1329	81,0	14,6	9,8 %
August	11 583	6 281	1207	74,4	14,8	11,6 %
September	7 939	1 340	661	38,7	14,0	9,2 %
October	8 896	0	547	37,1	16,3	25,6 %
November	3 450	0	293	14,4	11,8	12,7 %
December	2 077	0	234	8,7	8,9	6,6 %
TOTAL	113 080	20 073	8 017	554,8	16,6	13,9 %

* Solar productivity: Calculated in winter as the distributed hot energy divided by the collector surface, and in summer the distributed cold energy is divided by the collector surface but also by the thermal COP of the chiller.

Emergence program : mini annual thermal performance levels to reach

- Solar yield is estimated to 554,8 kWh/m².year >> **350 kWh/m².year**
- **Electrical COP** is estimated to **16,6 >> 5**

⇒ **Project eligible to the Emergence funds**

Lessons learnt from installation & first running

- **Architectural issues :**

- Existing building with a lot of caution in the architectural integration process



- **Installer skills :** very few installers skilled for both absorption / solar / control => learning process and high importance of engineering coordination



- **Building in use :** preventing any disturbance to companies/organizations working in the lower floors of the building

- **Evaporator circuit connection to the main chilled water circuit** of the building : need to move from the production side (high flow/low temperature difference) to the distribution side (lower flow / important temperature diff.) to optimize solar cooling input

First results

* **Nominal working conditions for domestic hot water production** since May 2012


* **Ongoing work preparation** to modify the solar chilled water introduction into the Net

* **Excess of available heat** in sunny days :
perfect safety functionality of the Drainback system against overheating

* Short test sequences :

- **checked capacity to run properly** the chiller
- **power balance** around the chiller :

- Generator : 28 kW – 80/77°C
- Evaporator : 18 kW – 7,5/10,5 °C
- Heat rejection : 46 kW – 31,5/34°C



Screen snapshot showing working system

Economics

Total cost of the project (cooling + DHW) : **330 000 €** (w/o eng.)

Public funding available for the project : **50%**

Final investment cost for the customer : **≈ 165 000€**

Savings :

- For cooling: * electric central heat pumps with average electrical SEER = 2

* electricity price = 0,04664 €/kWh

- For DHW production : * gas boiler (average η = 80%)

* gas price = 0,04182 €/kWh

Annual gross saving of \approx 8 000 €/year

Annual actualized saving during 20 years : **11 100€/year**

(average 6% /year increase for energy price)

Economics & Environment

ROI of the project not very performing (≈ 15 years) ...**BUT**

- Guarantee for the customer of performances (Emergence system)
- Considered as a Demo project (experiment + no profitable project (cover total cost on system life)

CO₂ savings from this solar cooling/DHW installation.

Hypothesis :

- For electricity: 120 g of CO₂/kWh
- For gas: 273 g of CO₂/kWh

=> **40 tons CO₂ / y**

Equivalent to **25 cars travelling 11 500 km/y**

1 car making
2 500 km/y
produces
350 kg CO₂



Conclusion

- **Project running since May 2012**
- **Start up / optimisation phase** in early Summer 2012
- **Very learnful first feedbacks**
- **Complete monitoring system** permitting future full feedback on energy performance level
- **Interesting new concept** for DHW/solar cooling :
 - **Maximal usability** of solar ressource & simplicity of the system
 - **Economical optimum** (gains for DHW + Cooling production)
 - **No risk of regular oversizing**
 - **Drainback strategy** in case of dysfunctionning
 - **First application** of the French Incentive Emergence Program
 - One case of mini **Solar District Heating/Cooling system**



SHC 2012 - San Francisco - 10th July 2011



Thanks for your attention !

Contact : Daniel Mugnier, TECSOL
daniel.mugnier@tecsol.fr

TECSOL